

South Carolina Regional Transmission Planning Stakeholder Meeting

Teams

February 28, 2024







Purpose and Goals for Today's Meeting

- Review and Discuss Key Assumptions and Data for the Next Planning Cycle
- Review and Discuss Major Transmission Expansion Plans
- Review Schedule for completing Transmission Planning Studies







Key Assumptions and Data for the Next Planning Cycle

DESC – Edward Chapman







Modeling Assumptions and Data

Dispersed Substation Load Forecast

- · Summer/Winter Peak, Off-Peak and Seasonal Load Levels
- Resource Planning provides 10 Year system load forecasts
- Transmission Planning creates dispersed substation load forecasts







Load Forecast Process


Resource Planning Input

- Develop 10-year projected forecast based on:
 - 10-year historical load summer and winter loads
 - Load factors by customer class
 - Considers weather, personal income, population growth, economic conditions, load management, energy efficiency, etc
 - Applies regression analysis to historical data to develop models
 - Applies forecasted growth rates to develop future projections





Load Forecast









Load Forecast Process

Transmission Planning Input

- Obtain summer and winter snapshot meter data from most recent seasons and adjust for load switching
- Develop 10-year projected forecast based on:
 - 10-year historical loading
 - Feedback from Distribution Planning, Local Managers, Large Industrial Group and Transmission Services Manager
- Wholesale loads are modeled as provided by the customer
- Dispersed forecasted load points are integrated into corporate load forecast







Modeling Assumptions and Data


Generation

- Annual generator ratings used
- Input from Generation Expansion Plan Reductions/Additions
- · Input from Generation Maintenance Schedule
- Generators dispatched economically
- Merchant Generators included





Existing Generation




DESC Owned Generation 5,665 MW






Merchant Generation







Future Generation Additions



Dispersed Solar 276 MW Transmission 0 MW Distribution







Interconnection Transitional Cluster

- 1754 MW of gas/solar/BESS generation in cluster
- Phase 2 restudy in progress
 - PV Only: 224.8 MW
 - Hybrid:
 - . 100 MW PV
 - . 100 MW BESS
 - BESS Only: 0 MW
 - Uprates: 144.2 MW
 - 469 MW Total







Interconnection DISIS 2023

- 3150 MW of gas/solar/BESS generation in cluster
- Phase 1 in progress
 - PV Only: 740 MW
 - Hybrid:
 - . 629 MW PV
 - 595 MW BESS
 - BESS Only: 998 MW
 - . Uprates: 124 MW
 - 2491 MW Total







Modeling Assumptions and Data

Transmission Network

- · Input from Transmission Plan
- · Neighboring Transmission Systems Modeled







Modeling Assumptions and Data Planned Transmission Facilities



2/22/2024

Planned Project	Tentative Completion Date
Modify Tap for Bushy Park 115kV Sub	Feb-24
astover - Square D 115kV - Rebuild	Jun-24
Church Creek - Ritter 230kV - Replace 25 Large Angles and Dead Ends	Jun-24
mory 230-23 kV Sub and Fold-in Construct	Jul-24
Palmetto Railways 115-13.8 kV Sub and Tap Construct	Aug-24
quare D - Hopkins 115kV: Rebuild	Sep-24
denwood Sub: #1 & #2 230-115kV Autobanks, Replace with 336MVA	Dec-24
iummerville: Replace and Spare 230-115kV 336MVA Auto Bank	Dec-24
Burton-St Helena 115kV: Rebuild Burton-Frogmore Transmission Section	Dec-24
Soose Creek Reservoir: Rebuild Transmission Line Crossings	Dec-24
Okatie 230–115kV Sub and the Jasper – Yemassee Fold In	Dec-24
Stevens Creek - Hooks 115kV/LR Plumb Branch 46kV Rebuilds	Dec-24
Coit – Gills Creek 115kV: Construct	Dec-24
Hooks - Thurmond 115kV Tie Rebuild	Dec-24
summerville 115 kV Loop Rebuild	Dec-24
Dkatie-Bluffton 115kV: Rebuild	Jun-25
Drangeburg #1 - Cameron Jct 46kV Line Rebuild	Jun-25
Cainhoy - Hamlin 115kV: Rebuild Line and Cainhoy – Hamlin 115 kV #2: Construct New 115 kV Line	Dec-25
asper – Okatie 230 kV #2: Construct	Dec-25
Riverport Tap: Construct Tap	Dec-25
it George - Sumter 230kV Tie: Rebuild Line from Santee Substation - Duke/Progress Energy Tie	Dec-25
Stevens Creek – Clarks Hill 115/46 kV Rebuild	Dec-25
Burton-St Helena 115kV: Frogmore Distribution - St Helena	Dec-25
Hopkins-CIP 230kV: Rebuild	Dec-25
Vagener 115kV Tap: Construct Tap	Dec-25
ackson 115-12 kV Sub and Tap ConstructkV	Dec-25
Satesburg - Saluda County 115kV: Rebuild Line	Dec-25
lat Rock 115-12kV Sub and Tap Construct	Dec-25
icout 230 kV Sub and Fold-in Construct	Mar-26
astover – Sumter 115kV DEP Tie: Rebuild with 1272 ACSR	May-26
Canadys – Ritter 115kV: Rebuild as 230/115kV Double Circuit	Jun-26
Jrguhart – Toolebeck 115kV line: Rebuild 477 ACSR sections	Aug-26
Dawson 230 kV Sub and Fold-in: Construct and Rebuild	Oct-26
Williams St Sub: Replace Sw House & Relays and McMeekin Sub: Add Sw House	Dec-26
/CS1-Denny Terrace 230kV & VCS1-Pineland 230kV: Rebuild Single Circuit Sections	Dec-26
Cameron – St Matthews 46kV: Rebuild	Dec-26
cameron Jct – Elloree 46 kV Rebuild	Dec-26
Harleyville 115KV Transmission Tap – Construct (1.4 miles)	Mar-27
Church Creek – Faber Place – Charleston Transmission: Add 230kV Line	May-27
Villiams-Summerville 230kV: Upgrade to SPDC B1272 ACSR	May-27
emassee— Ritter 230kV #1 & #2: Construct SPDC with B-1272	Jun-27
Union Pier 115-13.8 kV Sub: Tap	Dec-27
Atomic Road 115-12 kV Sub Construct	Dec-27
Clements Ferry 115–23kV Sub: Construct; Jack Primus–Cainhoy 115kV with Clements Ferry Tap Construct	Dec-27
Coast Guard 115 kV Tap: Construct	Dec-27
lloree – Santee City 46 kV: Rebuild	Dec-27







Modeling Assumptions and Data

System Interchange

- Firm scheduled transfers included
- Coordinated with Neighbors







Santee Cooper Transmission Planning Models Key Assumptions and Data

Weijian Cong







Major Model Components

Load Demand Forecast

Transmission Network

Generation Resources

Actual System Operations







Load Demand Forecast


- 10-year projected demand forecast
 - Wholesale customers load forecast
 - Industrial and municipality customer contracts
 - Santee Cooper Distribution load forecast
 - Transmission Planning produces dispersed substation load based on power factors derived from most recent meter data
- System Peak and off-peak load conditions







Santee Cooper 10-Year Actual & Load Forecast









Transmission Network

Models include:

- Existing transmission system and committed projects
- Neighboring transmission system representations
- All facilities assumed to be available unless notified otherwise
- Normal operating status (in-service or out-of-service) of facilities is represented







Transmission Network

- Uniform rating methodology is applied to transmission facilities
- Base case models are updated annually prior to annual transmission assessment
- Study models may be updated as needed prior to any study
- Neighboring and Regional system network from the latest MMWG models are used





Project Title	In-service Date
Johns Island – Queensboro (DESC) 115 kV Line	TBD
Varnville 230-115 kV transformer replacement	4/1/2024
Wassamassaw 230-115 kV Substation	10/31/2024
Kingstree 230 kV Series Bus Tie Breaker	12/1/2024
Conway 230 kV Switching Station	12/1/2025
Marion-Conway 230 kV Line	12/1/2025
Upgrade Purrysburg 230-115 kV Transformer	12/1/2025
Carolina Forest 230-115 kV Substation: Add Transformer	12/1/2025
Conway - Perry Road 230 kV Line	12/1/2025
Wassamassaw-Pringletown #1 and #2 115 kV Line	12/1/2025
Replace Bluffton-Purrysburg 230 kV limiting Elements	3/1/2026
Install 2nd Wassamassaw xfmr at Wassamassaw	5/30/2026
Cross - Wassamassaw 230 kV #2 Line	6/1/2026
Wassamassaw-Canebay 115 kV line	6/1/2026
Indian Field 230-115 kV Substation	6/30/2026
Indian Field-Wassamassaw 230 kV Line	6/30/2026
Purrysburg Station Improvements	9/1/2026
Upgrade Batesburg 230-115 kV transformer	12/1/2026
Varnville to Nixville tap 69 kV Rebuild to 115 kV	12/1/2026
Rebuild Kingstree-Hemingway 115 kV Line as a Double Circuit 230/115 kV Line	6/1/2027
Varnville 230-115 kV substation	6/30/2027
Varnville - Indian Field 230 kV line	12/1/2027
Chime Bell 115 kV Switching Station	12/1/2027
Marion - Red Bluff 230 kV line	6/1/2028








Generation Resources


Existing/Committed Generation

Cross Units 1- 4	J.S. Rainey Combined Cycle PB1
Winyah Units 1-4 (retire end of 2030)	J.S. Rainey 2A, 2B CTs
Hilton Head Turbines 1-3	J.S. Rainey 3-5 CTs
Myrtle Beach Turbines 1-5	Spillway Hydro
Jefferies Hydro 1, 2, 3, 4, 6	St. Stephen Hydro 1-3
Allendale (Merchant)	V.C. Summer #1 (shared output with DESC)
Cherokee Combined Cycle	Dorchester (Merchant)
Centerfield Solar (Merchant)	Domtar (Merchant)
Allora Solar (Merchant)	Gunsight Solar (Merchant)
Lambert I and II Solar (Merchant ISD 2024)	Landrace Solar (Merchant)











Resources Assumptions and Data

- Generation data is verified with Generation Department
- Seasonal models account for unit maintenance outages, known at the time, based on planned maintenance schedules
- Confirmed firm transmission service reservations
- SEPA allocations and other contracted purchases

Economic dispatch order is used for generator dispatch in base cases







Santee Cooper Planning Models Data and Assumptions

Questions?







Current DESC Transmission Expansion Plans

Alex Morrison








Disclaimer

- The projects described in these presentations represent the current transmission plans within the SCRTP footprint.
- The expansion plan is continuously reviewed and may change due to changes in key data and assumptions.
- This presentation does not represent a commitment to build.











DESC Planned Transmission Facilities





2/22/2024

	Tentative
Planned Project	Completion Date
Modify Tap for Bushy Park 115kV Sub	Feb-24
astover - Square D 115kV - Rebuild	Jun-24
thurch Creek - Ritter 230kV - Replace 25 Large Angles and Dead Ends	Jun-24
mory 230-23 kV Sub and Fold-in Construct	Jul-24
almetto Railways 115-13.8 kV Sub and Tap Construct	Aug-24
quare D - Hopkins 115kV: Rebuild	Sep-24
denwood Sub: #1 & #2 230-115kV Autobanks, Replace with 336MVA	Dec-24
Summerville: Replace and Spare 230-115kV 336MVA Auto Bank	Dec-24
Burton-St Helena 115kV: Rebuild Burton-Frogmore Transmission Section	Dec-24
Goose Creek Reservoir: Rebuild Transmission Line Crossings	Dec-24
Okatie 230–115kV Sub and the Jasper – Yemassee Fold In	Dec-24
tevens Creek - Hooks 115kV/LR Plumb Branch 46kV Rebuilds	Dec-24
coit – Gills Creek 115kV: Construct	Dec-24
Hooks - Thurmond 115kV Tie Rebuild	Dec-24
summerville 115 kV Loop Rebuild	Dec-24
Okatie-Bluffton 115kV: Rebuild	Jun-25
Orangeburg #1 - Cameron Jct 46kV Line Rebuild	Jun-25
ainhoy - Hamlin 115kV: Rebuild Line and Cainhoy – Hamlin 115 kV #2: Construct New 115 kV Line	Dec-25
asper – Okatie 230 kV #2: Construct	Dec-25
siverport Tap: Construct Tap	Dec-25
t George - Sumter 230kV Tie: Rebuild Line from Santee Substation - Duke/Progress Energy Tie	Dec-25
t George - Sumter 250kV Ne. Rebuild Line from Santee Substation - Duke/Progress Energy Ne tevens Creek – Clarks Hill 115/46 kV Rebuild	Dec-25
Jurton-St Helena 115kV: Frogmore Distribution - St Helena	Dec-25
topkins-CIP 230kV: Rebuild	Dec-25
Vagener 115kV Tap: Construct Tap	Dec-25
ackson 115-12 kV Sub and Tap ConstructkV	Dec-25
Batesburg - Saluda County 115kV: Rebuild Line	Dec-25
lat Rock 115-12kV Sub and Tap Construct	Dec-25
cout 230 kV Sub and Fold-in Construct	Mar-26
astover – Sumter 115kV DEP Tie: Rebuild with 1272 ACSR	May-26
Canadys – Ritter 115kV: Rebuild as 230/115kV Double Circuit	Jun-26
Jrquhart – Toolebeck 115kV line: Rebuild 477 ACSR sections	Aug-26
Dawson 230 kV Sub and Fold-in: Construct and Rebuild	Oct-26
Villiams St Sub: Replace Sw House & Relays and McMeekin Sub: Add Sw House	Dec-26
CS1-Denny Terrace 230kV & VCS1-Pineland 230kV: Rebuild Single Circuit Sections	Dec-26
ameron – St Matthews 46kV: Rebuild	Dec-26
ameron Jct – Elloree 46 kV Rebuild	Dec-26
larleyville 115KV Transmission Tap – Construct (1.4 miles)	Mar-27
hurch Creek – Faber Place – Charleston Transmission: Add 230kV Line	May-27
Villiams-Summerville 230kV: Upgrade to SPDC B1272 ACSR	May-27
emassee— Ritter 230kV #1 & #2: Construct SPDC with B-1272	Jun-27
Inion Pier 115-13.8 kV Sub: Tap	Dec-27
stomic Road 115-12 kV Sub Construct	Dec-27
lements Ferry 115–23kV Sub: Construct; Jack Primus–Cainhoy 115kV with Clements Ferry Tap Construct	Dec-27
coast Guard 115 kV Tap: Construct	Dec-27







DESC 2024 - 2028 Planned Transmission Facilities







Scout 230kV Sub and Fold-in: Construct

Project Description

Construct 230kV Transmission Line for Scout Customer Substation and modify VCS1 and Killian terminals.

Project Need

Load growth.

Project Status

Planned


Planned In-Service Date

March 2026















Dawson 230kV Sub and Fold-in: Construct and Rebuild

Project Description

Construct Dawson 230kV substation. Fold in the existing Canadys – Church Creek and Canadys – Faber Place 230kV lines at the Dawson 230kV substation (phase 1). Rebuild Canadys – Dawson 230kV #1 and #2 with B1272 ACSR (phase 2).

Project Need

Load growth.

Project Status

Planned

Planned In-Service Date

October 2025 (phase 1) and October 2026 (phase 2)













Ritter - Yemassee 230kV and 115kV Transmission System Expansion

Project Description

Construct Ritter – Yemassee 230kV #1 and #2 SPDC with B1272 ACSR on both sides. Convert the existing Ritter – Yemassee 230kV to 115kV operation. Convert and add terminals at Ritter and Yemassee. Add 230kV bus tie at Ritter and upgrade the Yemassee 230kV bus tie.

Project Need

This project is needed to improve system performance and to meet NERC TPL and internal DESC Planning Criteria for reliability. Adding additional 230kV and 115kV paths in the Yemassee, SC area mitigates potential overloads and provides more paths towards load in the Charleston, SC area.


Project Status

Planned

Planned In-Service Date













Eastover - Sumter 115kV DEP Tie: Rebuild with 1272 ACSR

Project Description

Upgrade the DESC section (approx. 1 mile) of the tie line from 397.5 ACSR Ibis to 1272 ACSR.

Project Need

This project is needed to improve system performance and to meet NERC TPL and internal DESC Planning Criteria for reliability.

Project Status


Planned

Planned In-Service Date

May 2026













Urquhart - Toolebeck 115kV Line: Rebuild 477 ACSR sections with 1272 ACSR

Project Description

Upgrade the 477 ACSR portions of the Urquhart – Toolebeck 115kV line to 1272 ACSR. Replace existing structures with Single Pole Double Circuit Structures. Approximately 12.5 miles.

Project Need

This project is needed to improve system performance and to meet NERC TPL and internal DESC Planning Criteria for reliability.

Project Status


Planned

Planned In-Service Date

August 2026











Load growth Projects

- Scout 230kV Sub and Fold-in: Construct
- Dawson 230kV Sub and Fold-in: Construct and Rebuild
- Union Pier 115-13.8 kV Sub: Tap
- Harleyville 115KV Transmission Tap Construct (1.4 miles)
- Riverport Tap: Construct Tap
- Wagener 115kV Tap: Construct Tap
- Coit Gills Creek 115kV: Construct
- Cainhoy 115kV Tap: Construct
- Jack Primus 115kV Tap: Construct
- Coast Guard 115kV Tap: Construct

Solar projects

- Lone Star Solar: Construct 230kV Switching Station
- Catalina Solar 115kV Switching Station: Construct
- Orangeburg County Solar: Construct 230kV Switching Station
- Jackson PV1 Solar 115kV Switching Station: Construct
 - Upgrade portions of Urquhart Salem SS 115kV from 336 to 1272 ACSR
 - Upgrade the Urquhart-Urquhart Junction portion of the Urquhart-Toolebeck 115kV line to 1272 ACSR







Questions?







Santee Cooper Major Transmission Expansion Plans

Emily Morgan





Project Title	In-service Date
Varnville 230-115 kV transformer replacement	4/1/2024
Wassamassaw 230-115 kV Substation	10/31/2024
Kingstree 230 kV Series Bus Tie Breaker	12/1/2024
Johns Island – Queensboro (DESC) 115 kV Line	12/1/2025
Conway 230 kV Switching Station	12/1/2025
Marion-Conway 230 kV Line	12/1/2025
Upgrade Purrysburg 230-115 kV Transformer	12/1/2025
Carolina Forest 230-115 kV Substation: Add Transformer	12/1/2025
Conway - Perry Road 230 kV Line	12/1/2025
Wassamassaw-Pringletown #1 and #2 115 kV Line	12/1/2025
Replace Bluffton-Purrysburg 230 kV limiting Elements	3/1/2026
Install 2nd Wassamassaw xfmr at Wassamassaw	5/30/2026
Cross - Wassamassaw 230 kV #2 Line	6/1/2026
Wassamassaw-Canebay 115 kV line	6/1/2026
Indian Field 230-115 kV Substation	6/30/2026
Indian Field-Wassamassaw 230 kV Line	6/30/2026
Purrysburg Station Improvements	9/1/2026
Upgrade Batesburg 230-115 kV transformer	12/1/2026
Varnville to Nixville tap 69 kV Rebuild to 115 kV	12/1/2026
Rebuild Kingstree-Hemingway 115 kV Line as a Double Circuit 230/115 kV Line	6/1/2027
Varnville 230-115 kV substation	6/30/2027
Varnville - Indian Field 230 kV line	12/1/2027
Chime Bell 115 kV Switching Station	12/1/2027
Marion - Red Bluff 230 kV line	6/1/2028







Wassamassaw 230-115kV Substation

Project Description

Fold in the existing Carnes-Cross 230 kV line and Jefferies-Harleyville 115 kV line into the new Wassamassaw 230-115kV Substation with the addition of one 230-115 kV transformer initially and 2nd transformer in the near future.

Project Need

Additional support is required for load growth in the Dorchester and Berkeley County area. This project is necessary to mitigate thermal loading issues under contingency conditions. The Wassamassaw 230-115kV Substation will be configured such that additional facilities can be added to provide support for continued load growth in the area.

Project Status

In progress


Planned In-Service Date

October 2024





Wassamassaw 230-115 kV Substation South Carolina Regional Transmission Planning









Kingstree 230 kV Series Bus Tie Breakers

Project Description

Reconfigure the Kingstree 230 kV Switching Station as required to install a second 230 kV Bus Tie Breaker in series with the existing 230 kV Bus Tie Breaker. Install redundant bus differential protection relays.

Project Need

The intent of this project is to mitigate thermal loading and voltage violations in multiple regions of the transmission system by eliminating a specific contingency that would result in loss of all 230 kV facilities at this station.

Project Status

Planned

Planned In-Service Date







John's Island (SC)-Queensboro (DESC) 115 kV Line

Project Description

Construct a new 115 kV transmission line using 1272 ACSR conductor, approximately 6 miles in length, from the Johns Island 230-115 kV Substation to a mutually agreed upon location on Johns Island. Construct a new 115 kV line terminal at Johns Island 230-115 kV Substation.

Project Need

This new interconnection will provide an additional transmission source to Johns Island, which will mitigate contingency conditions that could result in significant load loss, thus increasing transmission reliability to the Johns Island area.

Project Status

In Progress – Delayed due to construction permit through some areas


Planned In-Service Date

TBD





John's Island (SC)-Queensboro (DESC) 115 kV Line







South Carolina Regional Transmission Planning



Conway 230 kV Switching Station and Marion-Conway 230 kV Line

Project Description

Fold the Hemingway-Red Bluff 230 kV Line into the new Conway 230 kV Switching Station. Construct a 230 kV line approximately 34 miles in length from the Marion 230-115-69kV Substation to the Conway 230 kV Switching Station. Rebuild the existing Marion-Conway 115 kV Line for 230/115 kV double-circuit using bundled 1272 ACSR for the 230 kV line and single 795 ACSR for the 115 kV line.

Project Need

Studies indicate thermal loading and voltage violations under contingency conditions in the Horry-Georgetown area that are mitigated by the additional support that the Marion-Conway 230 kV Line provides. The new Conway Switching Station will also enable additional 230 kV network expansion in the area.


Project Status

In Progress

Planned In-Service Date













Carolina Forest 230-115 kV Transformer #1 Addition

Project Description

Extend the existing 230 kV bus at Carolina Forest 230-115kV Substation to install a second 230-115 kV transformer to operate in parallel to the existing transformer.

Project Need

Additional transformer at this substation will provide additional transformer capacity required to serve this area and alleviate thermal loading concerns on the existing transformer at this location under contingency conditions.

Project Status

In Progress

Planned In-Service Date







Conway - Perry Road 230 kV Line

Project Description

Construct a new 230 kV line between the Conway 230 kV Switching Station and the Perry Road 230-115 kV Substation using bundled 1272 ACSR conductor.

Project Need

The Conway – Perry Rd 230 kV Line will alleviate thermal loading exceedances under contingency conditions shown in planning assessments. To provide the necessary loading relief and voltage support to its transmission system, this new 230kV Line will upgrade existing infrastructure, improving reliability and meet the NERC Transmission Planning Reliability Standard. It will also provide additional network support to Horry County, a highly concentrated load area of the Santee Cooper system that includes Myrtle Beach that continues to see significant load growth.

Project Status


Planned

Planned In-Service Date





Conway – Perry Road 230 kV line









Wassamassaw - Pringetown #1 & #2 115 kV lines

Project Description

Construct a new double circuit 230/115 kV transmission lines, approximately 7 miles in length, from the Wassamassaw 230-115 kV Substation to the Pringletown 115 kV Switching Station. The 230 kV circuit will be operated at 115 kV using bundled 1272 ACSR and 115 kV circuit using single 1272 ACSR conductor.

Project Need

In addition to the proposed Wassamassaw 230-115 kV substation, these 115 kV lines will provide additional load serving capability for the load growth in the Camp Hall Commerce Park area.

Project Status


In progress

Planned In-Service Date





Wassamassaw – Pringletown #1 & #2 115 kV









Cross - Wassamassaw 230 kV #2 Line

Project Description

Construct a second 230 kV transmission line, approximately 18.3 miles in length, from the Cross 230 kV Switchyard to the Wassamassaw 230-115 kV Substation along existing transmission right-of-way and using pre-existing double-circuit structures where possible

Project Need

Adding a second Cross – Wassamassaw 230 kV line will mitigate thermal loading exceedances under contingency conditions. These exceedances violates planning criteria and does not meet NERC transmission planning reliability standard.

Project Status

In progress

Planned In-Service Date













Wassamassaw - Carnes 115 kV Line

Project Description

Construct a new 115 kV transmission line, approximately 6.45 miles, from the Wassamassaw 230-115 kV Substation to the Cane Bay 115 kV tap using existing right-of-way where possible.

Project Need

This project will provide a new networked 115 kV path into Carnes Crossroads 230-115 kV substation to help mitigate thermal loading exceedances under contingencies for existing load and future load growth in the area. These thermal loading exceedances do not meet the transmission system planning performance requirements under NERC Reliability Standard TPL-001-5 or Santee Cooper's internal planning criteria.

Project Status


In Progress

Planned In-Service Date





Wassamassaw – Cane Bay 115 kV line







Indian Field 230-115 kV Substation

Project Description

Fold in the existing Harleyville – St. George 115 kV line into the new Indian Field 230-115 kV substation. The existing Byrds Tap 115 kV line will be terminated on the 115 kV bus #1 at the new Indian Field 230-115kV substation. A new 115 kV transmission line will be built as a 230/115 kV double circuit line for future 230 kV projects from St. George 115 kV Switching Station to the new Indian Field 230-115kV substation.

Project Need

The new Indian Field substation will support the Southern Area load growth and enable additional 230 kV network expansion in the area.


Project Status

Committed

Planned In-Service Date













Indian Field - Wassamassaw 230 kV Line

Project Description

Construct a 230 kV transmission line from the proposed Indian Field 230-115 kV Substation to the Wassamassaw 230-115 kV Substation. Design and construct with bundled 1272 ACSR conductor rated for 2,400 Ampere continuous operation at 230kV.

Project Need

This 230 kV line and the proposed Indian Field 230-115 kV substation together provides support for the load growth in the Southern area. In addition, with the proposed Indian Field – Varnville 230 kV line, this project establishes an additional network path required to support economic power transfer from the Southern interface toward the load center.

Project Status


Committed

Planned In-Service Date





Indian Field – Wassamassaw 230 kV Line







Rebuild Kingstree - Hemingway 115 kV Line as a Double Circuit 230/115 kV Line

Project Description

Construct a second 230 kV line, approximately 22 miles, from the Kingstree 230 kV Switching Station to the Hemingway 230-115 kV Substation by rebuilding the existing Kingstree – Hemingway 115 kV line for double circuit 230/115 kV construction.

Project Need

This additional 230 kV line from Kingstree to Hemingway will help provide thermal loading relief and voltage support for the eastern area. This line also creates an additional path to the eastern area.

Project Status

Committed

Planned In-Service Date













Varnville 230-115 kV Substation

Project Description

Construct a new Varnville 230-115 kV substation on existing Santee Cooper transmission property and property acquired adjacent to the existing Varnville 230-115-69 kV Substation.

Project Need

Planning studies indicate the need to construct a new Varnville 230-115 kV substation to facilitate additional 230 kV transmission lines to support future transmission network expansion plans. The existing Varnville substation has space limitations and cannot accommodate additional 230 kV line terminals, transformation, and long-term plans to convert the 69 kV delivery points in the area to 115 kV service.


Project Status

Committed

Planned In-Service Date













Varnville - Indian Field 230 kV Line

Project Description

Construct a 230 kV transmission line (approximately 38 miles) from the Varnville 230-115 kV Substation to the proposed Indian Field 230-115 kV Substation. Rebuild the existing Bells Crossroads – Varnville 115 kV Line for 230/115 kV double-circuit on the existing right-of-way. Rebuild the St. George – Bells Crossroads (via Smoaks) 115 kV Line #2 for 230/115 kV double-circuit on the existing right-of-way until the 230 kV line reaches just outside of St George 115 kV Switching Station.

Project Need

Planning studies indicate this project and Indian Field-Wassamassaw 230 kV line project is necessary to add an additional path for bulk power transmission from Southern region to Eastern region. Existing Southern path via Yemassee and Mateeba is a contingency constraint seen in the near-term and long-term planning studies.

Project Status


Committed

Planned In-Service Date





Varnville - Indian Field 230 kV Line









Chime Bell 115 kV Switching Station

Project Description

The proposed Chime Bell 115 kV Switching Station will be constructed by folding in the existing Aiken #1 – Aiken #3 115 kV #1 line between the New Ellenton and Warrenville Delivery Point Taps. This switching station will break up the long transmission lines between Aiken 1 and Aiken 3 stations. The exposure to outages due to transmission line length will be reduced with the addition of Chime Bell.

Project Need

As part of coordinated transmission system expansion planning with Central Electric Power Cooperative, Inc., Santee Cooper has planned to construct the proposed Chime Bell 115 kV Switching Station to enhance the reliability of transmission service to the cooperative delivery points in the Aiken Area.

Project Status

Committed

Planned In-Service Date





Chime Bell 115 kV Switching Station









Marion - Red Bluff 230 kV Line

Project Description

Construct a new 230 kV transmission line from the Marion 230-115/230-69/115-69 kV Substation to the Red Bluff 230-115 kV Substation with bundled 1272 ACSR conductor rated for 2400 Ampere minimum continuous operation at 230 kV. Existing right-of-way will be used where possible, but new right-of-way will need to be obtained.

Project Need

Planning assessments have identified thermal loading and voltage violations under contingency conditions in the eastern region of the transmission system that are mitigated by the addition of a Marion – Red Bluff 230 kV Line. These thermal loading exceedances do not meet the transmission system planning performance requirements under NERC Reliability Standard or the planning criteria.

In addition, Santee Cooper's plans to retire Winyah Generating Station requires additional thermal and voltage support in this area to mitigate potential wide spread low voltage conditions under contingency conditions, which could pose serious risk to the reliability in the area and result in the need to curtail large amounts of load. This 230 kV line will also provide an additional source for a highly concentrated load area of the Santee Cooper system that continues to see significant load growth.

Project Status Committed
Planned In-Service Date June 2028





Marion – Red Bluff 230 kV line









Santee Cooper Transmission Expansion Plans


Questions?







Reliability Transmission Planning Studies Timeline









Next SCRTP Meeting

- Stakeholders will select up to 5 Economic Transmission Planning Studies
- Request Form will be posted on SCRTP website
- Review and discuss Multi-Party Assessment Studies
- SCRTP Email Distribution List will be notified
- Register online







South Carolina Regional Transmission Planning Stakeholder Meeting

Teams

February 28, 2024



